

CDBG-132-17

Questions from Potential Bidders

For Addendum 2

1. Question: Is there an engineering firm to contact?  
Answer: No
2. Question: Is there an Engineer's estimate?  
Answer: No
3. Question: Is there a specification cost?  
Answer: Not to exceed CDBG amount
4. Question: Are there drawings of the mechanical work needed?  
Answer: No
5. Question: Is there a coating survey on the interior and exterior?  
Answer: No
6. Question: What is the diameter and height of the tank?  
Answer: 64' diameter, 32' height
7. Question: Epoxy coating cannot be completed unless tank empty, please clarify.  
Answer: Use of temporary water storage tank will be required to complete this task
8. Question: There are repair items that cannot be completed while tank in service, such as adding a manway. Will you allow use of a temporary water storage tank?  
Answer: Yes
9. Question: What is the amount of grout material required?  
Answer: Unknown at this point. Will need a unit cost.
10. Question: Will you request a unit cost for extra cubic feet that may be needed?  
Answer: Yes, see attached revised proposal form.
11. Question: #15 PSI could push up on the roof causing rafters to buckle. Will this change?  
Answer: Yes, We are requesting PSI rating from tank manufacture and will supply when information is received.