

Consumer Confidence Report for Calendar Year 2018

Este informe contiene información muy importante sobre el agua usted bebe.
Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number		Public Water System Name	
AZ04-02019		Town of Huachuca City	
Contact Name and Title		Phone Number	E-mail Address
John Boise, Certified Operator, Grades 3 & 2		520-465-0251	jwboise@msn.com
We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>Jim Halterman, Public Works Supervisor</u> at <u>520-249-5241</u> for additional opportunity and meeting dates and times.			

Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s): (3) Ground Water Wells, #2 Cochise, #4 Skyline, #5 Howard

Drinking Water Contaminants

Microbial Contaminants: Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Inorganic Contaminants: Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

Pesticides and Herbicides: Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

Organic Chemical Contaminants: Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants: That can be naturally occurring or be the result of oil and gas production and mining activities.

Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

This PWS did not receive a SWAP because the PWS was either inactive at the time or the PWS did not exist.

Definitions

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria was present

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health

Maximum Residual Disinfectant Level (MRDL): The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method

Millirems per year (MREM): A measure of radiation absorbed by the body

Not Applicable (NA): Sampling was not completed by regulation or was not required

Not Detected (ND or <): Not detectable at reporting limit

Nephelometric Turbidity Units (NTU): A measure of water clarity

Million fibers per liter (MFL)

Picocuries per liter (pCi/L): Measure of the radioactivity in water

ppm: Parts per million or Milligrams per liter (mg/L)

ppb: Parts per billion or Micrograms per liter (µg/L)

ppt: Parts per trillion or Nanograms per liter (ng/L)

ppm x 1000 = ppb

ppq: Parts per quadrillion or Picograms per liter (pg/L)

ppb x 1000 = ppt

ppt x 1000 = ppq

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Town of Huachuca City, is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination
E. Coli	N	0	0	0	0	Human and animal fecal waste
Fecal Indicator (coliphage, enterococci and/or E. coli)	N	0	0	0	0	Human and animal fecal waste

Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	.25 ppm	.15 - .30 ppm	4	0	12-2018	Water additive used to control microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Haloacetic Acids (HAA5) (ppb)	N	< 2 ppb	0 – <2 ppb	60	N/A	6-2018	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	<.5 ppb	0 -.<.5 ppb	80	N/A	6-2018	Byproduct of drinking water disinfection
Lead & Copper	MCL Violation Y or N	90 th Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	.15 ppm	0	1.3	1.3	6-2016	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	2.6 ppb	0	15	0	6-2016	Corrosion of household plumbing systems; erosion of natural deposits
Radionuclides	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Alpha Emitters (pCi/L)	N	3.1 pCi/l	3.1 – 3.1 pCi/l	15	0	5-2016	Erosion of natural deposits
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) OR Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Arsenic ¹ (ppb)	N	2.1 ppb	0 – 2.1 ppb	10	0	5-2013	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Barium (ppm)	N	.26 ppm	.092 -.26 ppm	2	2	5-2013	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	N	.26 ppm	.13 - .26 ppm	4	4	5-2013	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate ² (ppm)	N	.79 ppm	.35 – 1.1 ppm	10	10	2-2018	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrite (ppm)	N	<.05 ppm	0 - <.05 ppm	1	1	5-2013	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	N	15.0 ppm	13.0 -18.0ppm	N/A	N/A	2-2018	Erosion of natural deposits

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions
DBP Monitoring Routine HAA5, THHM	Sampled but Lab was late in reporting to ADEQ	Sampled 6-11-2018 Corrected 8-8-2018	Resubmitted Lab Results to ADEQ 8-6-2018
Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.			



20¹⁸ Annual Consumer Confidence Report Mailing Waiver
(For Community Water Systems Serving < 10,000 People)

Public Water System Name: Town of Huachuca City

Public Water System Number: I.D. 02019

As outlined in Title 40, Code of Federal Regulations (CFR) § 141.155, as incorporated by reference in the Arizona Administrative Code R18-4-117, the Public Water System (PWS) named above hereby confirms that its Consumer Confidence Report (CCR) has been distributed to its customers. The PWS also certifies that the information contained in the CCR is correct and consistent with the compliance monitoring data previously submitted to the Arizona Department of Environmental Quality.

All community water systems must mail or otherwise direct deliver one copy of the report to each customer (defined as billing units or service connections) (use CCR Certification Form), except for systems serving < 10,000 people that may opt to meet the delivery requirements via the State of Arizona's CCR Waiver instead (use this Form).

Requirements for Community Water Systems Serving > 500 and < 10,000 Persons:

[X] The PWS Certifies That All of the Following Were Performed:

- Inform customers it will not be providing copies of the CCR by mail or other direct delivery methods; and
Publish the entire report annually in one (or more) local newspaper or other news media serving areas in which the system's customers are located; and
Make copies of the CCR available to the public upon request; and
Keep copies available for a period of three (3) years.

Requirements for Community Water Systems Serving <= 500 Persons:

[] The PWS Certifies That All of the Following Were Performed:

- Inform customers it will not be providing copies of the CCR by mail or other direct delivery methods; and
Make copies of the CCR available to the public upon request; and
Keep copies available for a period of three (3) years.

Certified by:

Name & Signature: JAMES A HALTERMAN [Signature]

Title: Public Works Supervisor

Phone #: (520) 456-1354 Date: 20190614